



ACCREDITATION CERTIFICATE

Issued under the authority of Bangladesh Accreditation Act, 2006
by Bangladesh Accreditation Board (BAB), Ministry of Industries to

Summit Testing and Calibration Laboratory

Summit Power Limited, Holding No#231, P.O#Rupshi

Tetlabo, Barpa, Rupganj, Narayanganj-1460, Bangladesh

This is to certify that this


Testing Laboratory

is accredited in accordance with the international standard

ISO/IEC 17025:2017

in respect of the associated scope, subject to the terms and
conditions governing the relevant conformity assessment
body (CAB) accreditation.

Certificate Number : **01.061.21**
Accreditation Date : **28 June 2021**
Date of Issuance : **19 May 2026 (1st Renewal)**
Date of Expiration : **27 June 2027**



A. Aminul Islam
19.05.26
Mohd. Aminul Islam
Director General

This certificate must be returned on request; reproduction must follow BAB guidelines. For the specific scopes to which this accreditation applies, please refer to the Directory of CABs at BAB website.

SCOPE OF ACCREDITATION

CAB Name & Address: Summit Testing & Calibration Laboratory.
Holding No:231, P.O:Rupshi,Tetlabo,Barpa,Rupganj,Narayanganj-1460

Accreditation Standard: ISO/IEC 17025:2017

Accreditation Date: 28 June 2021

Certificate Number : 01.061.21

Issued on : 19 May 2026

(1st Renewal)

Last Amended on : N/A

Valid until : 27 June 2027

S.N.	Products/ Materials/ Items of test	Type of tests performed	Specifications/Standard test methods/Techniques used	Range of testing/Limit of detection
Field: Electrical Testing				
1	Electrical Insulating Oil	Dielectric Strength Of Transformer Oil	IEC 60156/IS-6792	Max 60kV
2	Electrical	Earth Resistance Test	IEEE 81	Resistance Range: 0.010Ω- 19.99kΩ
3	Electrical	Soil Resistivity Test	IEEE 81	Resistance Range: 0.010Ω- 19.99kΩ
4	Electrical	Insulation Resistance Measurement	IEEE 43/JCGM-100	Test Voltage:250V- 5000V Insulation Resistance:0-2TΩ
5	Electrical	Low Resistance/Contact Resistance Measurement	IEC-62812/JCGM-100	Resistance Range: 0.1μΩ- 2.0kΩ

END



BAB Quality Manager