



Project : Integrated Agriculture Development Project (IADP).

BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,

RAJSHAHI.

Sinking & Drilling Contractor

M/s M.R drilling & Construction

Hazipara, Thakurgaon.

BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY, RAJSHAHI.

Engineer

DRILLING LOG.

Plot No. : 162

J.L No. : 53

Mouza : Chuchuli.

Union : Bolrampur.

Upazilla : Atwari.

District : Panchagath.

DTW No : A-BMDA-

Date Strated : 17/06/14

At : 9.00 A.M

Logged By : (Md. Golam Mostafa)

Sub-Assistant Engineer

B.M.D.A, Panchagath Zone Panchagath.

A.M Rod length : 3.00 Meter

Drilling Time Log

Graphic Log

Thickness (Meter)

Description of Formation.

Remarks

Rod From To

From To

From To

Description of Formation.

Remarks

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

1 2 3 4 5 6 7 8

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagath Zone
Panchagath.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagath Zone
Panchagath.

For The Contractor
M/s M.R drilling & Construction
Hazipara, Thakurgaon.



Project : Integrated Agriculture Development Project (IADP).

BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,

RAJSHAHI.

Sinking & Drilling Contractor

M/s M.R drilling & Construction

Hazipara, Thakurgaon.

BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY, RAJSHAHI.

Engineer

CONSTRUCTION DETAILS.

DTW No : A-BMDA-
District : Panchagarth.
Upazilla : Atwari.
Union : Botrampur.
Mouza : Chuchuli.
J.L No. : 53
Plot No. : 162

Operation	Started	Completed
Drilling	21/06/14 At 9.00	21/06/14 At 10.00
Casing	21/06/14 At 11.00	21/06/14 At 15.00
Gravel placing	21/06/14 At 15.30	21/06/14 At 17.30
Drilling Diameter	0.6096 Meter	

Housing pipe (Diameter) : 0.3556 Meter (Mild Steel / PVC)

UWC : M.S 0.60 M. above G.L.

UWC Including Reducer : M.S 30.40 M. below G.L.

Lapping (With Reducer) : 0.00 M. Total Fixture length (M.) : 31.00

LWC pipe (Diameter) : 0.203 Meter (Mild Steel / PVC)

Depth below G.L. : From : PVC 30.40 M. To 30.40 M.

Lapping : 0.00 M. Total Fixture length (M.) : 0.00

Screen pipe (Diameter) : 0.203 Meter (SS/ FG/ LCS/ PVC - Robo)

Depth below G.L. : From : PVC 30.40 M. To 30.40 M.

Lapping : 0.00 M. Total Fixture length (M.) : 0.00

Screen pipe (Diameter) : 0.203 Meter (SS/ FG/ LCS/ PVC)

Depth below G.L. : From : PVC 30.40 M. To 30.40 M.

Lapping : 0.00 M. Total Fixture length (M.) : 0.00

Ball plug (Diameter) : 0.203 Meter (SS/ FG/ LCS/ PVC)

Depth below G.L. : From : PVC 54.25 M. To 54.25 M.

End Cap : 0.203 Meter (SS/ FG/ LCS/ PVC)

Depth below G.L. : From : PVC 54.25 M. To 54.25 M.

Centralizers : 54, 48, 42, 39, 36 M. Total Number : 5 Nos.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.


Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Cross Section of the Well. (Not to scale).



Material Used	Housing (Inc.Reducer)+LWC (Blind Pipe)+Well Screen+Ball Plug = 31.00 M. + 0.00 M. + 24.00 M. + 1.52 M. = 56.52 M
Lapping	Housing (Inc.Reducer)+LWC (Blind Pipe)+Well Screen+Ball Plug = 0.00 M. + 0.00 M. + 0.15 M. + 0.00 M. = 0.15 M

G.L. থেকে Ball Plug এর নীচে Gravel's বসানো হয়েছে।

Verticality Test : Maximum Deviation : 4.105 Centimeter. at 30.00 Meter Depth.

Fixture Length (Excluding lapping of Joint). From up to UWC bottom of Ball Plug. Total Fixture length (M.) : 56.37 M.

Total Quantity : 13.794 Cum.

Gravel Quantity (Approximately) : 13.794 Cum. To 55.770 M.

Depth below G.L. At : From : 0.00 M. To 55.77 M.

Centralizers : 54, 48, 42, 39, 36 M. Total Number : 5 Nos.

End Cap : 0.203 Meter (SS/ FG/ LCS/ PVC)

Depth below G.L. : From : PVC 54.25 M. To 54.25 M.

Ball plug (Diameter) : 0.203 Meter (SS/ FG/ LCS/ PVC)

Depth below G.L. : From : PVC 54.25 M. To 54.25 M.

Lapping : 0.00 M. Total Fixture length (M.) : 0.00

Screen pipe (Diameter) : 0.203 Meter (SS/ FG/ LCS/ PVC - Robo)

Depth below G.L. : From : PVC 30.40 M. To 30.40 M.

Lapping : 0.00 M. Total Fixture length (M.) : 0.00

LWC pipe (Diameter) : 0.203 Meter (Mild Steel / PVC)

Depth below G.L. : From : PVC 30.40 M. To 30.40 M.

Lapping (With Reducer) : 0.00 M. Total Fixture length (M.) : 31.00

Housing pipe (Diameter) : 0.3556 Meter (Mild Steel / PVC)

UWC : M.S 0.60 M. above G.L.

UWC Including Reducer : M.S 30.40 M. below G.L.

Lapping : 0.00 M. Total Fixture length (M.) : 31.00

Sub-Assistant Engineer
B.M.D.A, Panchagath Zone
Panchagath.

727278
Golam Mostafa)

Suspension of Height (H) :	3.00	Meter	Dia of UWC : d-1:	35.56	Centimeter.	Dia of Disc : d-2:	31.75	Centimeter.
----------------------------	------	-------	-------------------	-------	-------------	--------------------	-------	-------------

1	Total Length of Deep Tube Well	56.37	Meter
2	Length of UWC (Excluding Reducer)	30.00	Meter

Date : 21/06/14

		Project : Integrated Agriculture Development Project (IADP).	
BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY, RAJSHAHI.		Engineer	
Sinking & Drilling Contractor		M/s M.R drilling & Construction Hazipara, Thakurgaon.	
DTW No. : A-BMDA-	District : Panchagarih.	Upazilla : Atwar.	Union : Boltrampur.
			Mouza : Chuchuli.
			J.L No. : 53
			PLOT No. : 162
Before & After Shrouding.			



Project : Integrated Agriculture Development Project (IADP).
BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,
RAJSHAHI.
DEVELOPMENT RECORD
(Preiod : 2.00 Hours)

DTW No : A-BMDA-
District : Panchagarh
Upazilla : Atwari
Union : Bolrampur
Mouza : Chuchuli
J.L No. : 53
Plot No. : 162
Page No : 1

Date : 26/06/14
Starting Time : 8.00 hrs
Ref. Mark (Top of Housing) : 0.60 Meter above G.L.
Static Water Level : 2.337 Meter below top of Housing Pipe.
Size of Orifice : 0.125 Meter
Length of UWC : 30.00 Meter
Capacity of Pump : 0.0850 Cumec.
Size of Delivery Pipe : 0.150 Meter
Depth of Pump Setting : 25.00 Meter

Time	Pizometric Height (Meter)	Discharge (Cumec.)	Pumping Water level below Reference Mark (Meter)	Actual Draw - Down (Meter)	Remarks.
1	2	3	4	5	6
00 mn (0.00 hrs)			2.337		50 % Discharge.
05 mn	0.3430	0.0288	4.726	2.388	0.0288 Cumec.
10 mn	0.3430	0.0288	4.751	2.414	
15 mn	0.3430	0.0288	4.802	2.465	
20 mn	0.3430	0.0288	4.853	2.515	
25 mn	0.3430	0.0288	4.878	2.541	
30 mn	0.3430	0.0288	4.929	2.592	
35 mn	1.3465	0.0566	7.774	5.436	
40 mn	1.3465	0.0566	7.799	5.462	100 % Discharge.
45 mn	1.3465	0.0566	7.825	5.487	
50 mn	1.3465	0.0566	7.863	5.525	
55 mn	1.3465	0.0566	7.901	5.563	
60 mn	1.3465	0.0566	7.926	5.589	
65 mn	1.3465	0.0566	7.977	5.640	
70 mn	2.1341	0.0708	9.667	7.330	
80 mn	2.1341	0.0708	9.718	7.381	125 % Discharge.
90 mn	2.1341	0.0708	9.756	7.419	
100 mn	2.8709	0.0850	10.671	8.333	
110 mn	2.8709	0.0850	10.721	8.384	150 % Discharge.
120 mn (2.00 hrs)	2.8709	0.0850	10.798	8.460	

1 Cumec. : 1000.00 LPS.

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagarh Zone
Panchagarh.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagarh Zone
Panchagarh.

For The Contractor
M/s M.R drilling & Construction
Hazipara, Thakurgaon.



Project : Integrated Agriculture Development Project (IADP).
BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,
RAJSHAHIL.
RECOVERY RECORD
(Period : 1.00 Hours)

DTW No	: A-BMDA-
District	: Panchagarih.
Upazilla	: Atwari.
Union	: Bolrampur.
Mouza	: Chuchuli.
J.L No.	: 53
Plot No.	: 162
Page No	: 2

Date	: 26/06/14
Starting Time	: 10.00 hrs
Ref. Mark (Top of Housing)	: 0.60 Meter above G.L.
Static Water Level	: 2.337 Meter below top of Housing Pipe.
Size of Orifice	: 0.125 Meter
Length of UWC	: 30.00 Meter
Capacity of Pump	: 0.085 Cumec.
Depth of Pump Setting	: 25.00 Meter
Size of Delivery Pipe	: 0.15 Meter

Time	Water level below Reference Mark (Meter)	Remarks.
1	2	3
00 mn (2.00 hrs)	10.798	
01 mn	3.151	
02 mn	3.023	
03 mn	2.973	
04 mn	2.922	
05 mn	2.846	
07 mn	2.770	
09 mn	2.706	
11 mn	2.668	
13 mn	2.617	
15 mn	2.566	
20 mn	2.541	
25 mn	2.490	
30 mn	2.465	
40 mn	2.452	
50 mn	2.426	
60 mn (3.00 hrs)	2.414	

1 Cumec. : 1000.00 LPS.

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagarih Zone
Panchagarih.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagarih Zone
Panchagarih.

15/12/14

For The Contractor
M/s M.R drilling & Construction
Hazipara, Thakurgaon.



Project : Integrated Agriculture Development Project (IADP).

BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,

RAJSHAHI.

SAND TEST RECORD

(Period : 1.00 Hours)

DTW No : A-BMDA-	District : Panchagath.	Upazilla : Atwar.	Union : Bolrampur.	Mouza : Chuchuli.	J.L. No. : 53	Plot No. : 162	Page No : 3
------------------	------------------------	-------------------	--------------------	-------------------	---------------	----------------	-------------

Date	: 26/06/14
Starting Time	: 11.00 hrs
Ref. Mark (Top of Housing)	: 0.60 Meter above G.L.
Static Water Level	: 2.337 Meter below top of Housing Pipe.
Size of Orifice	: 0.125 Meter
Length of UWC	: 30.00 Meter
Capacity of Pump	: 0.085 Cumec.
Depth of Pump Setting	: 25.00 Meter
Size of Delivery Pipe	: 0.15 Meter

Time	1	2	3	4
Water level below Reference Mark (Meter)				
00 mn (3.00 hrs)	2.414			
01 mn	10.061			
02 mn	10.163			
03 mn	10.302			
04 mn	10.391			
05 mn	10.468			
07 mn	10.518			
09 mn	10.569			
11 mn	10.595			
Observed result :				
(a) After 5 minutes : <100..... ppm.				
(b) After 10 minutes : < 30..... ppm.				
Accepted sand content after 5 minutes.				
100 ppm and after 10 minutes 30 ppm.				
N.B :				
01 mn	10.061			
02 mn	10.163			
03 mn	10.302			
04 mn	10.391			
05 mn	10.468			
07 mn	10.518			
09 mn	10.569			
11 mn	10.595			
13 mn	10.620			
15 mn	10.645			
20 mn	10.671			
25 mn	10.696			
30 mn	10.709			
40 mn	10.747			
50 mn	10.773			
60 mn (4.00 hrs)	10.836			
Sand Content				
Remarks				

1 Cumec. : 1000.00 LPS.

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagath Zone
Panchagath.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagath Zone
Panchagath.

For The Corporation
M/s M.R drilling & Construction
Hazipara, Thakurgaon.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagarth Zone
Panchagarth.

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagharh Zone
Panchagharh.

For The Contractor
M/s M.R drilling & Construction
Hazipara, Thakurgaon.

I Cumec. : 1000.00 LPS.

Time	1	2	3	4	5	6
Pizometric Height (Meter)	00 mn (4.00 hrs)	2.8709	0.0850	10.836		
	05 mn	2.8709	0.0850	10.366	8.029	
	10 mn	2.8709	0.0850	10.493	8.155	
	15 mn	2.8709	0.0850	10.595	8.257	
	20 mn	2.8709	0.0850	10.696	8.359	
	30 mn	2.8709	0.0850	10.747	8.410	
	40 mn	2.8709	0.0850	10.772	8.435	
	50 mn	2.8709	0.0850	10.798	8.460	
	60 mn	2.8709	0.0850	10.823	8.486	
	75 mn	2.8709	0.0850	10.849	8.511	
	90 mn	2.8709	0.0850	10.861	8.524	
	120 mn	2.8709	0.0850	10.874	8.537	
	150 mn	2.8709	0.0850	10.900	8.562	
	180 mn	2.8709	0.0850	10.912	8.575	
	210 mn	2.8709	0.0850	10.925	8.587	
	240 mn (8.00 hrs)	2.8709	0.0850	10.950	8.613	
Discharge (Cumec.)						
Pumping Water level below Reference Mark (Meter)						
Actual Draw - (Meter)						
Remarks.						

Date	: 26/06/14			
Starting Time	: 12.00	hrs	0	minute,
Ref. Mark (Top of Housing)	: 0.60	Meter	above G.L.	
Static Water Level	: 2.337	Meter	below top of Housing Pipe.	
Size of Orifice	: 0.125	Meter		
Length of UWC	: 30.00	Meter		
Capacity of Pump	: 0.085	Cumec.		
Size of Delivery Pipe	: 0.15	Meter		
Depth of Pump Setting	: 25.00	Meter		

DTW No. : A-BMDA-	District : Panchagargh.	Upazilla : Atwari.	Union : Bolrampur.	Mouza : Chuchuli.	J.L. No. : 53	Plot No. : 162	Page No : 4
-------------------	-------------------------	--------------------	--------------------	-------------------	---------------	----------------	-------------

DTW No	: A-BMDA-
District	: Panchagath
Upazilla	: Atwari
Union	: Bolrampur
Mouza	: Chuchuli
J.L No.	: 53
Plot No.	: 162
Page No	: 5

BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,
RAJSHAHI.
PUMP TEST RECORD
(Preiod : 1.00 Hours) 150% Discharge.



Date	: 26/06/14
Starting Time	: 16.00
Ref. Mark (Top of Housing)	: 0.60
Static Water Level	: 2.337
Size of Orifice	: 0.125
Length of UWC	: 30.00
Capacity of Pump	: 0.085 Cumec.
Size of Delivery Pipe	: 0.15
Depth of Pump Setting	: 25.00

Time	Pizometric Height	Discharge (Cumec.)	Pumping Water level below Reference Mark (Meter)	Actual Draw - Down (Meter)	Remarks
1	2	3	4	5	6
00 mn (8.00 hrs)	2.8709	0.0850	10.950	8.613	
01 mn	2.8709	0.0850	10.950	8.613	
02 mn	2.8709	0.0850	10.950	8.613	
03 mn	2.8709	0.0850	10.950	8.613	
04 mn	2.8709	0.0850	10.950	8.613	
05 mn	2.8709	0.0850	10.950	8.613	
06 mn	2.8709	0.0850	10.950	8.613	
07 mn	2.8709	0.0850	10.950	8.613	
09 mn	2.8709	0.0850	10.950	8.613	
11 mn	2.8709	0.0850	10.950	8.613	
13 mn	2.8709	0.0850	10.950	8.613	
15 mn	2.8709	0.0850	10.950	8.613	
20 mn	2.8709	0.0850	10.963	8.626	
25 mn	2.8709	0.0850	10.963	8.626	
30 mn	2.8709	0.0850	10.963	8.626	
40 mn	2.8709	0.0850	10.963	8.626	
50 mn	2.8709	0.0850	10.963	8.626	
60 mn (9.00 hrs)	2.8709	0.0850	10.963	8.626	

I Cumec. : 1000.00 LPS.

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagath Zone
Panchagath.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagath Zone
Panchagath.

For The Contractor
M/s M.R drilling & Construction
Hazipara, Thakurgaon.

15/12/14



Project : Integrated Agriculture Development Project (IADP).
BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,
RAJSHAHI.
RECOVERY RECORD
(Preiod : 2.50 Hours) 150% Discharge.

DTW No : A-BMDA-	District : Panchagarth.	Upazilla : Atwari.	Union : Bolrampur.	Mouza : Chuchuli.	J.L No. : 53	Plot No. : 162	Page No : 6
------------------	-------------------------	--------------------	--------------------	-------------------	--------------	----------------	-------------

Date	26/06/14	Strating Time	17.00	hrs	0	minute,	Capacity of Pump	0.085	Cumec.
Ref. Mark (Top of Housing)	0.60	Meter	above G.L.						
Static Water Level	2.337	Meter	bellow top of Housing Pipe.				Size of Delivery Pipe	0.15	Meter
Size of Orifice	0.125	Meter					Depth of Pump Setting	25.00	Meter
Length of UWC	30.00	Meter							

Time	Water level below Reference Mark (Meter)	Remarks
1	2	3
00 mn (9.00 hrs)	10.963	Pumping discontinued.
02 mn	2.795	
04 mn	2.719	
06 mn	2.642	
08 mn	2.592	
10 mn	2.541	
15 mn	2.515	
20 mn	2.490	
25 mn	2.465	
30 mn	2.452	
40 mn	2.439	
50 mn	2.426	
60 mn	2.414	
75 mn	2.401	
90 mn	2.388	
105 mn	2.376	
120 mn	2.363	
135 mn	2.350	
150 mn (11.50 hrs)	2.340	

1 Cumec. : 1000.00 LPS.

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagarth Zone
Panchagarth.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagarth Zone
Panchagarth.

For The Contractor,
M/s M.R drilling & Construction
Hazipara, Thakurgaon.



Project : Integrated Agriculture Development Project (IADP).
BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,
RAJSHAHI.
MULTIPLE STEP TEST
(Preiod : 4.50 Hours)

DTW No : A-BMDA-	Page No : 7
District : Panchagadh.	Plot No. : 162
Upazilla : Atwari.	J.L.No. : 53
Union : Bolrampur.	Mouza : Chuchuli.

Date : 26/06/14	Starting Time : 19.50	hrs	0	minute,	Capacity of Pump : 0.085	Cumec.
Ref. Mark (Top of Housing) : 0.60	Meter	above G.L.				
Static Water Level : 2.337	Meter	bellow top of Housing Pipe.				
Size of Office : 0.125	Meter	Size of Delivery Pipe : 0.15	Meter			
Length of UWC : 30.00	Meter	Depth of Pump Setting : 25.00	Meter			

Time	Pizometric Height (Meter)	Discharge (Cumec.)	Pumping Water level (Meter)	Actual Draw - Down (Meter)	Remarks.
1	2	3	4	5	6
00 mn (11.50 hrs)			2.340		
10 mn	1.3465	0.0566	7.824	5.487	
20 mn	1.3465	0.0566	7.850	5.513	
30 mn	1.3465	0.0566	7.875	5.538	
45 mn	1.3465	0.0566	7.951	5.614	
60 mn	1.3465	0.0566	7.977	5.640	
90 mn	1.3465	0.0566	7.978	5.640	
100 mn	2.1341	0.0708	9.680	7.343	
120 mn	2.1341	0.0708	9.693	7.355	
135 mn	2.1341	0.0708	9.706	7.368	
150 mn	2.1341	0.0708	9.756	7.419	
180 mn	2.1341	0.0708	9.807	7.470	
190 mn	2.8709	0.0850	10.671	8.333	
200 mn	2.8709	0.0850	10.696	8.359	
210 mn	2.8709	0.0850	10.747	8.409	
225 mn	2.8709	0.0850	10.798	8.461	
240 mn	2.8709	0.0850	10.823	8.486	
270 mn (16.00 hrs)	2.8709	0.0850	10.849	8.511	
					0.0850 Cumec.

Static Water Level (S.W.L)	2.337	Meter	or	7.667	Feet
Pumping Water Level (P.W.L)	10.849	Meter	or	35.583	Feet
Final Discharge	0.085	Cumec.	or	3.000	Cusec.
Specific Draw Down	100.131	Meter / Cumec.	or	9.306	Feet / Cusec.

(Md. Golam Mostafa)
 Sub-Assistant Engineer
 B.M.D.A, Panchagadh Zone
 Panchagadh.

(Eng. Md. Faridul Islam)
 Assistant Engineer
 B.M.D.A, Panchagadh Zone
 Panchagadh.

For The Contractor
 M/s R drilling & Construction
 Hazipara, Thakurgaon.

15/12/14



Project : Integrated Agriculture Development Project (IADP).

**BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,
RAJSHAHI.
COMPLETION CERTIFICATE OF PUMP HOUSE.**

DTW No : A-BMDA- District : Panchagarih. Upazilla : Atwari. Union : Bolrampur. Mouza : Chuchuli. J.L No. : 53 Plot No. : 162	Engineer BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY, RAJSHAHI.	Date of Starting : 28/06/14	
		Date of Completion : 20/07/14	
	Sinking & Drilling Contractor M/s M.R drilling & Construction Hazipara, Thakurgaon.	Page No : 8	

Certified that the contractor has completed the construction work of Pump House successfully at the above mentioned site as per specification in accordance with clause-8 of the General Specification and Special Terms & Conditions of contracts.

Following works have been completed specifically and checked the works personally.

SL. No.	Description of Works	Completed (Yes / No).	Remarks.
1	Plastering Work	Yes	
2	Slab Casting	Yes	
3	Roof Casting	Yes	
4	Discharge Box	No	
5	White Washing	Yes	
6	Lime Tracing / Bitumin emulsion	Yes	
7	Fitting of door made Metal sheet with proper paint	Yes	
8	Pump base	Yes	
9	R.C.C Beam	Yes	0" - 1 1/2" (inch) dia Rod Hook used in R.C.C Beam.
10	Ditch filling or Site Development	Yes	
11	Lock and Key supply (2 Nos.)	Yes	
12			
13			

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagarih Zone
Panchagarih.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagarih Zone
Panchagarih.

For The Contractor
M/s M.R drilling & Construction
Hazipara, Thakurgaon.

15/12/14



Project : Integrated Agriculture Development Project (IADP).

BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY,
RAJSHAHI.

COMPLETION CERTIFICATE OF PUMP HOUSE.

Engineer		BARIND MULTIPURPOSE DEVELOPMENT AUTHORITY, RAJSHAHI.		Date of Starting : 03/03/15	
Sinking & Drilling Contractor		M/s M.R drilling & Construction Hazipara, Thakurgaon.		Date of Completion : 25/03/15	
DTW No : A-BMDA-	District : Panchagarh.	Upazilla : Atwari.	Union : Bolrampur.	Mouza : Duhusuh.	J.L No. : 52
					Plot No. : 205
Page No : 8					

Certified that the contractor has completed the construction work of Pump House successfully at the above mentioned site as per specification in accordance with clause-8 of the General Specification and Special Terms & Conditions of contracts.

Following works have been completed specifically and checked the works personally.

SL. No.	Description of Works	Completed (Yes / No).	Remarks.
1	Plastering Work	Yes	4
2	Slab Casting	Yes	
3	Roof Casting	Yes	
4	Discharge Box	No	
5	White Washing	Yes	
6	Lime Tracing / Bitumin emulsion	Yes	
7	Fitting of door made Metal sheet with proper paint	Yes	
8	Pump base	Yes	
9	R.C.C Beam	Yes	
10	Ditch filling or Site Development	Yes	0' - 1 1/2" (Inch) dia Rod Hook used in R.C.C Beam.
11	Lock and Key supply (2 Nos.)	Yes	
12			
13			

(Md. Golam Mostafa)
Sub-Assistant Engineer
B.M.D.A, Panchagarh Zone
Panchagarh.

(Eng. Md. Faridul Islam)
Assistant Engineer
B.M.D.A, Panchagarh Zone
Panchagarh.

M/s M.R drilling & Construction
For the Contractor
Hazipara, Thakurgaon.

25/03/15