

Queries/ Requests by the Potential Bidders and Clarifications/ Responses by the ACCESS-BLPA project.

Name of the Package: Development of Benapole Land Port -Construction of Yards, Sheds, Warehouses, Transshipments Sheds with other ancillary facilities

Package No.: BLPA/W2

Tender ID: 1029432

Pre-Bid meeting closing date and time: 26-Dec-2024, 17:00

SI	Queries/Requests by the Bidders	Clarification/ Responses by the ACCESS-BLPA Project.
1.	<p>a. Under clause 15.1(b) the Specific Experience sought for within a period of last five (5) years counting backward from the date of publication of IFT;</p> <p>b. Recently we have purchased Bid documents for Package-W4: Development of Bhomra Land Port - Construction of parking yard, sheds and warehouse with other ancillary facilities. The specific experience sought for a period between 1st January 2014 and bid submission deadline i.e. more than 10 years.</p> <p>c. We have also purchased Bid documents for Package-W7: Development of Burimai Land Port Construction of parking yard, sheds and warehouse with other ancillary facilities. The specific experience sought for this bid is also for a period between 1st January 2014 and bid submission deadline i.e. more than 10years.</p> <p>d. Both the above projects are under your jurisdiction.</p> <p>e. Due to COVID-19 in the last few years, the construction work activities were, in different civil engineering departments were less. As such in last five years the contractors has less work experience.</p> <p>Considering the above facts we request your honor to extend the Specific Experience period from five (05) years to ten (10) years.</p> <p>This will allow more contractors to participate in the mentioned Bid.</p>	<p>Tender Data Sheet, Clause 15.1 (b), the existing text “The minimum specific experience as a Prime Contractor or Subcontractor or Management Contractor in construction works of at least one (1) contract of similar nature, complexity and methods/construction technology successfully completed within the last five (5) years, with a value of at least Tk. 100.00 Crore (Taka one hundred crore); years counting backward from the date of publication of IFT in the newspaper”</p> <p>Will be replaced as follows-</p> <p>“The minimum specific experience as a Prime Contractor or Subcontractor or Management Contractor in construction works of at least one (1) contract of similar nature, complexity and methods/ construction technology successfully completed within the last ten (10) years, with a value of at least Tk. 100.00 Crore (Taka one hundred crore); years counting backward from the</p>

www

da

→

Sl	Queries/Requests by the Bidders	Clarification/ Responses by the ACCESS-BLPA Project.
		<p>date of publication of IFT in the newspaper”</p> <p>Other text will remain unchanged.</p> <p>Amendment in e-GP system for Tender Data Sheet, Clause 15.1 (b) will be done.</p>

www

dm


 (Md. Ruhul Amin Miah)
 Project Director (Joint Secretary)
 (Service ID-15346)
 Land Port Building
 F-19/A, Sher-E-Bangla Nagar, Agargaon,
 Dhaka-1207, Bangladesh.
 E-mail: pdaccessblpa@gmail.com

Queries/ Requests by the Potential Bidders and Clarifications/ Responses by the ACCESS-BLPA project.

Name of the Package: Construction of Port Building , Parking Facilities for Passengers with ancillary works at Benapole Land Port

Package No.: BLPA/W1

Tender ID: 1029301

Pre-Bid meeting closing date and time: 26-Dec-2024, 17:00

Sl	Queries/Requests by the Bidders	Clarification/ Responses by the ACCESS-BLPA Project.
1.	<p>a. Under clause 15.1(b) the Specific Experience sought for within a period of last five (5) years counting backward from the date of publication of IFT;</p> <p>b. Recently we have purchased Bid documents for Package-W4: Development of Bhomra Land Port Construction of parking yard, sheds and warehouse with other ancillary facilities. The specific experience sought for a period between 1st January 2014 and bid submission deadline i.e. more than 10 years.</p> <p>c. We have also purchased Bid documents for Package-W7: Development of Burimai Land Port Construction of parking yard, sheds and warehouse with other ancillary facilities. The specific experience sought for this bid is also for a period between 1st January 2014 and bid submission deadline i.e. more than 10years.</p> <p>d. Both the above projects are under your jurisdiction.</p> <p>e. Due to COVID-19 in the last few years, the construction work activities were, in different civil engineering departments were less. As such in last five years the contractors has less work experience.</p> <p>Considering the above facts we request your honor to extend the Specific Experience period from five (05) years to ten (10) years. This will allow more contractors to participate in the mentioned Bid.</p>	<p>Tender Data Sheet, Clause 15.1 (b), the existing text “The minimum specific experience as a Prime Contractor or Subcontractor or Management Contractor in construction works of at least one (1) contract of similar nature, complexity and methods/construction technology successfully completed within the last five (5) years, with a value of at least Tk. 80.00 Crore (Taka eighty crore), years counting backward from the date of publication of IFT in the newspaper.”</p> <p>Will be replaced as follows-</p> <p>“The minimum specific experience as a Prime Contractor or Subcontractor or Management Contractor in construction works of at least one (1) contract of similar nature, complexity and methods/construction technology successfully completed within the last ten (10) years, with a value of at least Tk. 80.00 Crore (Taka eighty crore), years counting backward from the date of publication of IFT in the newspaper.”</p> <p>Other text will remain unchanged.</p>

Sl	Queries/Requests by the Bidders	Clarification/ Responses by the ACCESS-BLPA Project.
		Amendment in e-GP system for Tender Data Sheet, Clause 15.1 (b) will be done
2.	Item No. 82.4 (Civil), Pile Load test, Load Capacity Not Mentioned, Please informed Us.	Allowable Load Bearing Capacity of Pile 85 Ton Amendment in e-GP system for Item No.: 82.4 (civil) of BOQ will be done
3.	Item No. 275 (Sanitary), Detail Description Not Mentioned, Please mentioned it.	Complete development of the tube well by suitable air compressor and pump of suitable capacity by alternate surging and pumping until satisfactory yield, sand free water and the turbidity condition is reached using necessary quantity of calgon and conducting step draw down test before and after the development as per specification and accepted by the Engineer-in-charge. (Development should be started within 24 hours of completion of shrouding). Amendment in e-GP system for Item No. 275 (Sanitary) of BOQ will be done



www.


 05.01.2025
 (Md. Ruhul Amin Miah)
 Project Director (Joint Secretary)
 (Service ID-15346)
 Land Port Building
 F-19/A, Sher-E-Bangla Nagar, Agargaon,
 Dhaka-1207, Bangladesh.
 E-mail: pdaccessblpa@gmail.com