



110 MLD Surface Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 06-09-2024

Test No: 1885

Weather: Cloudy

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 09:19 AM	Sampling Time: 09:40 AM	Sampling Time: 09:50 AM	Sampling Time: 10:50 AM	Sampling Time: 11:00 AM	Sampling Time: 11:10 AM		
1	Temperature	°C	day	20-30	HI-98107/ Electrometric			28.9	29.5	29.2	29.1		
2	pH		day	6.5-8.5				7.9	7.5	7.7	7.8		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	366	45.7	45.4	1.9	0.52	0.23		
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			207	35	15	11		
5	Suspended Solid	mg/L	day	...				315	34	34	2	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable		
7	Total residual chlorine	mg/L	Twice a week	0.2-0.4	USEPA DPD Method1								0.33
8	Sulfate	mg/L	Once a week	400	USEPA1 SulfaVer 4 Method2	9							
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	30						30
10	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	126.1	121.4						125.9
Remark:													