



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 18-03-2022

Test No: 983

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:14 AM	Sampling Time: 9:30 AM	Sampling Time: 10:00 AM	Sampling Time: 10:30 AM	Sampling Time: 10:48 AM	Sampling Time: 11:00 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			27.4	26.6	27.1	27.4
2	pH		day	6.5-8.5				8.23	7.17	7.74	7.81
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	89	11.2	11	1.24	0.43	0.34
4	Color	pt-co	day	15	Portable analyser-AQ3700			29	0	0	0
5	Suspended Solid	mg/L	day	...				25	5	5	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Sulphate	mg/L	Once a week	400	DR 3900						
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	40				
Remark:											