



110 MLD Surface Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Record of Plant Apparatus

Date: 18-11-2024

Weather: Sunny

Sl No	Test Item	Unit	Instrument Name	Parshall Flume	Pre Filter-1	Pre Filter-2	CWR
				Time: 10:52 AM	Time: 11:35 AM	Time: 11:37 AM	Time: 11:57 AM
1	pH		KROHNE pH Meter	8.49			7.59
2	Turbidity	NTU	KROHNE Turbidity Meter	24.6	2.9	0	0.14
3	Total Residual Chlorine	mg/L	KROHNE Chlorine Meter	0			0.21
.							