



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 23-05-2022

Test No: 1049

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 9:18 AM	Sampling Time: 9:30 AM	Sampling Time: 9:50 AM	Sampling Time: 11:40 AM	Sampling Time: 12:20 PM	Sampling Time: 12:30 PM		
1	Temperature	°C	day	20-30	Portable analyser-ST300			28.5	28.7	28.5	28.8		
2	pH		day	6.5-8.5				7.87	7.43	7.48	7.71		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	212	25.2	25.2	8.2	1.4	0.99		
4	Color	pt-co	day	15	Portable analyser-AQ3700			75	31	7	0		
5	Suspended Solid	mg/L	day	...				96	9	9	2	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total Aluminium	mg/L	Once a week	<0.2	DR3900								0.2
8	Total residual chlorine	mg/L	Twice a week	0.2									0.28
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	50						

Remark: