



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 22-03-2022

Test No: 987

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 9:15 AM	Sampling Time: 9:30 AM	Sampling Time: 11:20 AM	Sampling Time: 12:07 PM	Sampling Time: 12:15 PM	Sampling Time: 12:20 PM
1	Temperature	°C	day	20-30	Portable analyser-ST300			28.8	28.2	28.3	28.3
2	pH		day	6.5-8.5				7.97	7.37	7.55	7.76
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	77.3	10.7	10.4	1.09	0.47	0.25
4	Color	pt-co	day	15	Portable analyser-AQ3700			30	0	0	0
5	Suspended Solid	mg/L	day	...				34	4	4	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			40	40		
Remark:											