



# 110 MLD Surface Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

## Daily Water Quality Report of Laboratory

Date of Testing: 25-10-2024

Test No: 1934

Weather: Cloudy

SI No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 08:30 AM	Sampling Time: 09:10 AM	Sampling Time: 09:20 AM	Sampling Time: 10:02 AM	Sampling Time: 10:12 AM	Sampling Time: 10:19 AM
1	Temperature	°C	day	20-30	HI-98107/ Electrometric			28.1	28.3	28.3	28.4
2	pH		day	6.5-8.5				7.8	7.6	7.7	7.6
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	146	28.4	28.3	1.9	0.55	0.26
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			123	31	17	12
5	Suspended Solid	mg/L	day	...				88	18	18	1
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable
7	Sulfate	mg/L	Once a week	400	USEPA1 SulfaVer 4 Method2						
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	30				
9	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	128.5	123.5			125	
<b>Remark:</b>											