



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 10-08-2022

Test No: 1128

Weather: Cloudy

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 9:25 AM	Sampling Time: 9:30 AM	Sampling Time: 10:20 AM	Sampling Time: 11:05 AM	Sampling Time: 11:20 AM	Sampling Time: 11:30 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			28.9	28.7	28.8	28.9
2	pH		day	6.5-8.5				8.17	7.86	7.76	7.66
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	431	76.1	76.1	3.17	0.81	0.34
4	Color	pt-co	day	15	Portable analyser-AQ3700			438	35	14	4
5	Suspended Solid	mg/L	day	...				521	74	74	3
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Calcium	mg/L	Once a week	75	CaH Titration						
8	ORP	mv	Once a week	...	WTW pH/ ION 3310						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			20	20		
Remark:											