



110 MLD Surface Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 06-11-2024

Test No: 1946

Weather: Sunny

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 09:50 AM	Sampling Time: 10:10 AM	Sampling Time: 10:40 AM	Sampling Time: 11:18 AM	Sampling Time: 11:30 AM	Sampling Time: 11:42 AM		
1	Temperature	°C	day	20-30	HI-98107/ Electrometric			28.5	28	28	28.5		
2	pH		day	6.5-8.5				7.9	7.8	7.8	7.8		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	102	15.3	14.8	1.95	0.47	0.25		
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			55	36	15	12		
5	Suspended Solid	mg/L	day	...				85	15	14	2	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable		
7	ORP	mv	Once a week	...	WTW pH/ ION 3310								219.2
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	30						30
9	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	138.1	131.2						132.4
Remark:													