



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 19-11-2021

Test No: 864

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 8:30 AM	Sampling Time: 9:00 AM	Sampling Time: 10:20 AM	Sampling Time: 10:50 AM	Sampling Time: 11:15 AM	Sampling Time: 11:30 AM		
1	Temperature	°C	day	20-30	Portable analyser-ST300			25.5	25.9	25.8	26		
2	PH		day	6.5-8.5				8.16	7.88	7.79	7.62		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	150	23.5	23	1.2	0.39	0.1		
4	Color	pt-co	day	15	Portable analyser-AQ3700			77	16	0	0		
5	Suspended Solid	mg/L	day	...				146	13	13	0	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total residual chlorine	mg/L	Twice a week	0.2	DR3900								0.28
8	Fluoride	mg/L	Once a week	1									0.26
9	Sulphate	mg/L	Once a week	400									7
10	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	40					40	
Remark:													