



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 04-03-2023

Test No: 1334

Weather: Sunny

SI No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:00 AM	Sampling Time: 9:50 AM	Sampling Time: 10:10 AM	Sampling Time: 11:30 AM	Sampling Time: 11:45 AM	Sampling Time: 11:58 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			28.6	28.1	28.4	27
2	pH		day	6.5-8.5				7.91	7.8	7.83	7.89
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	63.7	14.1	13.8	1.99	0.81	0.22
4	Color	pt-co	day	15	Portable analyser-AQ3700			62	15	6	0
5	Suspended Solid	mg/L	day	...				62	10	10	2
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable
7	Oxygen -Dissolved	mg/L	Once a week	6	Portable analyser-ST300D						
8	Nitrogen-Nitrite	mg/L	Once a week	<1	USEPA Diazotization Method1						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			40	30		
Remark:											