



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 10-09-2022

Test No: 1159

Weather: Cloudy

SI No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water	
						Sampling Time: 9:34 AM	Sampling Time: 9:50 AM	Sampling Time: 10:00 AM	Sampling Time: 10:45 AM	Sampling Time: 10:53 AM	Sampling Time: 11:00 AM	
1	Temperature	°C	day	20-30	Portable analyser-ST300			30.8	31	30.6	30.4	
2	pH		day	6.5-8.5				7.4	7.29	7.16	6.96	
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	553	157	157	12.3	1.7	0.99	
4	Color	pt-co	day	15	Portable analyser-AQ3700			500	56	28	15	
5	Suspended Solid	mg/L	day	...				603	168	168	8	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable	
7	Nitrogen-Nitrate	mg/L	Once a week	10	Cadmium Reduction Method							0.7
8	Nitrogen-Nitrite	mg/L	Once a week	<1	USEPA Diazotization Method1							
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	20	20			20		
Remark:												