



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 26-10-2022

Test No: 1205

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 9:54 AM	Sampling Time: 10:00 AM	Sampling Time: 10:30 AM	Sampling Time: 11:15 AM	Sampling Time: 11:25 AM	Sampling Time: 11:30 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			27.9	28	28	27.9
2	pH		day	6.5-8.5				7.23	7.14	7.09	7.06
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	509	77.5	77	5.47	0.32	0.13
4	Color	pt-co	day	15	Portable analyser-AQ3700			358	33	0	0
5	Suspended Solid	mg/L	day	...				483	66	66	5
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Calcium	mg/L	Once a week	75	Portable analyser-AQ3700						
8	ORP	mv	Once a week	...	WTW pH/ ION 3310						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			20	20		
Remark:											