



# 110 MLD Surface Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

## Daily Water Quality Report of Laboratory

Date of Testing: 26-09-2024

Test No: 1905

Weather: Rain

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water	
						Sampling Time: 10:00 AM	Sampling Time: 10:10 AM	Sampling Time: 10:30 AM	Sampling Time: 10:55 AM	Sampling Time: 11:10 AM	Sampling Time: 11:20 AM	
1	Temperature	°C	day	20-30	HI-98107/ Electrometric			27.3	26.7	26.8	27.4	
2	pH		day	6.5-8.5				8	7.7	7.8	7.8	
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	299	57.4	57.1	1.9	0.88	0.17	
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			263	34	14	9	
5	Suspended Solid	mg/L	day	...				253	45	45	1	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable	
7	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	133.8	121.2					124.5
8	Salinity	PSU	Once a week	...								0.173
9	Conductivity	µS/cm	Once a week	...								253
10	Resistivity	Ω-cm	Once a week	...								3953
11	Chloride	ppm	day	150-600		Mercuric Nitrate Titration	30					30
<b>Remark:</b>												