



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 04-09-2022

Test No: 1153

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:00 AM	Sampling Time: 10:30 AM	Sampling Time: 10:40 AM	Sampling Time: 11:09 AM	Sampling Time: 11:18 AM	Sampling Time: 11:30 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			30.4	30.4	30	30
2	pH		day	6.5-8.5				7.88	7.5	7.05	7.06
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	589	117.2	117	7.23	0.54	0.54
4	Color	pt-co	day	15	Portable analyser-AQ3700			500	41	12	15
5	Suspended Solid	mg/L	day	...				682	122	122	6
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable
7	Alkalinity	mg/L	Once a week	...	H2SO4 Titration						
8	Hardness	mg/L	Once a week	200-500	Portable analyser-AQ3700						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			20	20		
Remark:											