



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 25-09-2021

Test No: 809

Weather: Cloudy

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 11:40 AM	Sampling Time: 10:20 AM	Sampling Time: 10:25 AM	Sampling Time: 11:10 AM	Sampling Time: 11:20 AM	Sampling Time: 11:30 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			30.4	30.7	30.5	30.5
2	PH		day	6.5-8.5				7.93	7.58	7.47	7.48
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	187	26.1	25.4	0.88	0.5	0.21
4	Color	pt-co	day	15	Portable analyser-AQ3700			107	3	0	0
5	Suspended Solid	mg/L	day					148	27	27	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Oxygen -Dissolved	mg/L	Once a week	6	Portable analyser-ST300D						
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	40				
Remark:											