



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 24-11-2021

Test No: 869

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water	
						Sampling Time: 9:30 AM	Sampling Time: 9:45 AM	Sampling Time: 10:25 AM	Sampling Time: 11:00 AM	Sampling Time: 11:15 AM	Sampling Time: 11:30 AM	
1	Temperature	°C	day	20-30	Portable analyser-ST300			27.1	26.7	26.8	27.3	
2	PH		day	6.5-8.5				7.8	7.67	7.61	7.63	
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	105	35.9	35.8	2.56	0.48	0.26	
4	Color	pt-co	day	15	Portable analyser-AQ3700			56	0	0	0	
5	Suspended Solid	mg/L	day	...				96	34	34	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable	
7	Calcium	mg/L	Once a week	75	EDTA Titration							70
8	ORP	mv	Once a week	...	WTW PH ION 3310							
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			40	40			
Remark:												