



110 MLD Surface Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 08-11-2024

Test No: 1948

Weather: Sunny

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:00 AM	Sampling Time: 10:10 AM	Sampling Time: 10:20 AM	Sampling Time: 10:55 AM	Sampling Time: 11:05 AM	Sampling Time: 11:15 AM
1	Temperature	°C	day	20-30	HI-98107/ Electrometric			28.7	28.9	29.1	29.2
2	pH		day	6.5-8.5				7.9	7.6	7.7	7.8
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	71.4	16.9	16.7	1.96	0.46	0.29
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			61	31	17	12
5	Suspended Solid	mg/L	day	...				46	12	12	2
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable
7	Sulfate	mg/L	Once a week	400	USEPA1 SulfaVer 4 Method2						
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	30				
9	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	141.8	130.8			132.8	
Remark:											