



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 09-11-2022

Test No: 1219

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 9:51 AM	Sampling Time: 10:00 AM	Sampling Time: 10:30 AM	Sampling Time: 11:15 AM	Sampling Time: 11:30 AM	Sampling Time: 11:37 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			27.3	27	26.5	26.8
2	pH		day	6.5-8.5				7.53	7.38	7.34	7.32
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	88.6	16.1	16.1	3.94	0.23	0.11
4	Color	pt-co	day	15	Portable analyser-AQ3700			207	17	6	0
5	Suspended Solid	mg/L	day	...				72	12	12	1
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Calcium	mg/L	Once a week	75	Portable analyser-AQ3700						
8	ORP	mv	Once a week	...	WTW pH/ ION 3310						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			20	20		
Remark:											