



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 28-02-2023

Test No: 1330

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 09:28 AM	Sampling Time: 09:38 AM	Sampling Time: 10:05 AM	Sampling Time: 10:30 AM	Sampling Time: 10:48 AM	Sampling Time: 11:00 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			24.8	24.8	24.8	25.3
2	pH		day	6.5-8.5				7.93	7.82	7.76	7.77
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	133	17.6	17	1.98	0.69	0.17
4	Color	pt-co	day	15	Portable analyser-AQ3700			68	14	9	5
5	Suspended Solid	mg/L	day	...				122	13	13	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			40	30		

Remark: