



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 21-04-2022

Test No: 1017

Weather: Sunny

SI No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 9:15 AM	Sampling Time: 9:30 AM	Sampling Time: 10:00 AM	Sampling Time: 10:30 AM	Sampling Time: 10:45 AM	Sampling Time: 10:50 AM		
1	Temperature	°C	day	20-30	Portable analyser-ST300			30	29.7	29.4	30		
2	pH		day	6.5-8.5				8.36	7.34	7.56	7.71		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	67	11	10.6	1.26	0.25	0.1		
4	Color	pt-co	day	15	Portable analyser-AQ3700			27	0	0	0		
5	Suspended Solid	mg/L	day	...				35	2	2	0	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total Dissolved Solids	ppm	Once a week	1000	Portable analyser-A222 & A322								223.9
8	Salinity	PSU	Once a week	...									0.271
9	Conductivity	µS/cm	Once a week	...									455.9
10	Resistivity	Ω-cm	Once a week	...									2194
11	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	50	50					50	

Remark: