



110 MLD Surface Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 02-12-2024

Test No: 1972

Weather: Sunny

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 10:10 AM	Sampling Time: 10:30 AM	Sampling Time: 10:45 AM	Sampling Time: 11:10 AM	Sampling Time: 11:28 AM	Sampling Time: 11:40 AM		
1	Temperature	°C	day	20-30	HI-98107/ Electrometric			25.3	25.4	25.3	26.2		
2	pH		day	6.5-8.5				7.9	7.7	7.7	7.7		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	78.3	12.4	12.2	1.54	0.63	0.18		
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			49	26	18	9		
5	Suspended Solid	mg/L	day	...				51	6	6	0	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total Aluminium	mg/L	Once a week	0.2	Eriochrome Cyanine R Method1								0.031
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	30						30
9	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	173.2	156.3						159.3
Remark:													