



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 11-06-2022

Test No: 1068

Weather: Sunny

SI No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water	
						Sampling Time: 7:40 AM	Sampling Time: 8:00 AM	Sampling Time: 8:05 AM	Sampling Time: 8:45 AM	Sampling Time: 8:55 AM	Sampling Time: 9:00 AM	
1	Temperature	°C	day	20-30	Portable analyser-ST300			29	28.5	28.5	28.6	
2	pH		day	6.5-8.5				7.35	7.28	7.34	7.22	
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	43.6	11.1	11	3.23	0.72	0.44	
4	Color	pt-co	day	15	Portable analyser-AQ3700			69	30	1	0	
5	Suspended Solid	mg/L	day	...				33	6	6	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable	
7	Oxygen -Dissolved	mg/L	Once a week	6	Portable analyser-ST300D							
8	Nitrogen-Nitrate	mg/L	Once a week	10	Cadmium Reduction Method							
9	Nitrogen-Nitrite	mg/L	Once a week	<1	USEPA Diazotization Method1							
10	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	40					
Remark:												