



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 28-07-2022

Test No: 1115

Weather: Sunny

SI No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 8:54 AM	Sampling Time: 9:10 AM	Sampling Time: 9:50 AM	Sampling Time: 10:25 AM	Sampling Time: 10:40 AM	Sampling Time: 10:50 AM		
1	Temperature	°C	day	20-30	Portable analyser-ST300			29.5	29.2	28.9	28.5		
2	pH		day	6.5-8.5				7.97	7.68	7.47	7.39		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	81.7	17.8	17.8	1.74	0.37	0.14		
4	Color	pt-co	day	15	Portable analyser-AQ3700			88	9	3	1		
5	Suspended Solid	mg/L	day	...				57	9	9	0	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total Dissolved Solids	ppm	Once a week	1000	Portable analyser-A222 & A322								131.8
8	Salinity	PSU	Once a week	...									0.18
9	Conductivity	µS/cm	Once a week	...									268
10	Resistivity	Ω-cm	Once a week	...									3732
11	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	20	20					20	

Remark: