



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 26-02-2023

Test No: 1328

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:19 AM	Sampling Time: 10:25 AM	Sampling Time: 10:45 AM	Sampling Time: 11:05 AM	Sampling Time: 11:20 AM	Sampling Time: 11:36 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			25.4	25.1	24.5	25.2
2	pH		day	6.5-8.5				7.88	7.66	7.65	7.69
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	99.9	11.9	11.8	1.47	0.79	0.37
4	Color	pt-co	day	15	Portable analyser-AQ3700			63	2	0	0
5	Suspended Solid	mg/L	day	...				94	9	9	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Alkalinity	mg/L	Once a week	...	H2SO4 Titration						
8	Hardness	mg/L	Once a week	200-500	Portable analyser-AQ3700						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			40	20		
Remark:											