



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 11-03-2022

Test No: 976

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 12:00 PM	Sampling Time: 10:00 AM	Sampling Time: 10:10 AM	Sampling Time: 11:30 AM	Sampling Time: 11:40 AM	Sampling Time: 11:50 AM		
1	Temperature	°C	day	20-30	Portable analyser-ST300			25.1	25	25.5	25.5		
2	pH		day	6.5-8.5				7.47	7.22	7.33	7.42		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	66.1	8.86	8.69	0.79	0.35	0.23		
4	Color	pt-co	day	15	Portable analyser-AQ3700			29	0	0	0		
5	Suspended Solid	mg/L	day	...				42	4	4	0	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total residual chlorine	mg/L	Twice a week	0.2	DR3900								0.28
8	Fluoride	mg/L	Once a week	1									0.16
9	Sulphate	mg/L	Once a week	400									17
10	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	40					40	
Remark:													