



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 11-11-2021

Test No: 856

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 11:17 AM	Sampling Time: 9:50 AM	Sampling Time: 10:06 AM	Sampling Time: 10:44 AM	Sampling Time: 10:55 AM	Sampling Time: 11:07 AM		
1	Temperature	°C	day	20-30	Portable analyser-ST300			28.4	28.1	27.9	28.2		
2	PH		day	6.5-8.5				7.91	7.48	7.43	7.4		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	184	29.3	29.1	2.1	0.35	0.11		
4	Color	pt-co	day	15	Portable analyser-AQ3700			149	5	0	0		
5	Suspended Solid	mg/L	day	...				183	23	22	0	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total Dissolved Solids	ppm	Once a week	1000	Portable analyser-A222 & A322								155.3
8	Salinity	PSU	Once a week	...									0.203
9	Conductivity	µS/cm	Once a week	...									316
10	Resistivity	Ω-cm	Once a week	...									3165
11	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	40					40	

Remark: