

Tender Notice


Request For Quotation (RFQ)

Date of Submission 27.4.2025 to 29.04.2025

Submitted to Deputy General Manager (EMM&QTD) Former
Electrical & Corrosion Control Department (8th Floor) At Head Office of Titas Gas Kawran Bazar

Technical Specification of 2 Ton (24000 BTU/HR), Split Type (Non- Inverter) AC

Sl no	Description	Quantity
1	<p>Supply, installation, testing & commissioning of split type air-cooler with Non-inverter comprising condensing and evaporating units having following cooling capacity based on indoor temperature 27±30±C DB/ 19.5"-22±C WB and outdoor temperature 35±40±C DB at high fan speed condition suitable for installation & operation in tropicalized country like Bangladesh & as per detailed specifications & standard as mentioned below:</p> <p>OUTDOOR UNIT/CONDENSING UNIT</p> <p>(1). Type: Compact weather proof outdoor type condensing unit (2). Compressor Hermitically sealed reciprocating / rotary compressor. (3). Refrigerant Internationally accepted & recommended and most commonly used gas (CFC free) (4). Blower motor Well balanced type direct driven centrifugal type blower fan (5). Power supply:(5.1). 200-250 V, single phase, 50 Hz. AC supply [up to 30000BTU/HR] (5.2). 380-440 V 3-phase, 50 Hz. AC supply [above 30000 BTU/HR] (6). Condensing pipe coil Made of copper 7) EER COP: For up to 60000 BTU/HR EER should be minimum 9.23 (BTU/HR/WATT and COP Should be minimum 2.70 (W/W) For above 60000 BTU/HR FER should be minimum 10.5 (BTU/HR) WATT and COP should be minimum 3.08 (W/W)(8) Others features (8.1) Well balanced in all respect having interlock with the fan coil unit . (8.2). Compressor dully equipped with vibration isolator, thermostatic & overload controls, magnetic contactors and all other standard accessories complete. (8.3). Refrigerant copper pipe [From outdoor to indoor unit] with thermal insulation, refrigerant charging arrangement etc. [Minm length10 mtr.] (8.4). Reqd. size PVC insulated & sheathed cable with ECC through water grade PVC pipe from outdoor to indoor unit. (8.5) Sound level: maximum 65 dB(A) at 1 meter</p> <p>INDOOR UNIT/FAN COIL UNIT</p> <p>Features: (1). Direct expansion system fan coil unit with well-balanced direct driven centrifugal type fan. (2). Fancy & adjustable air circulating louver grill, removable & washable type filter (3). Condensing water drain out PVC flexible pipe with necessary insulation (4). Thermostatic switch and remote control switch. (5). Sound level: maximum 44 dB(A) at 1 meter</p> <p>Standard Major component shall be manufactured as per relevant international standard & code Documents Manufacturing company shall have the following certificate (1). ISO-9001. (2). CE Certification UL Listing</p> <p>Warranty -The bidder should provide the guaranty of compressor for at least 2 years & free service with spares for 2 years from the date of commissioning & it should be obtained from the air cooler selling agency. Brand Like Gree, Media, Carrier, Walton, Haier, Hisense manufactured or assembled in BANGLADESH/ CHINA approved by the engineer in accordance with fulfillment of the above specifications and having relevant certificates as mentioned. Capacity : 2 Ton (24000 BTU/HR), Split Type(Non- Inverter) AC</p>	01(One) Set
1.1	Capacity : 24000 BTU/HR, Split Type (Non-Inverter)	06Pcs
2	Angle	06 Set
3	Installation, Testing, Commissioning of The A/C set with necessary accessories.	06 Job
4	Mobilization Charge	01 Job
5	Necessary Papers Submitted along with Quotation- Communicating Persons Name, Mobile & E-mail, Trade License, Bank Solvency, Tax Certificate and Technical	


 Deputy General Manager
 "Engr: Md Shamsuzzoha"
 Mobile-01939921229